

**BILL SUMMARY**  
1<sup>st</sup> Session of the 60<sup>th</sup> Legislature

<b>Bill No.:</b>	<b>HB2459</b>
<b>Version:</b>	<b>CS</b>
<b>Request Number:</b>	<b>13274</b>
<b>Author:</b>	<b>Rep. Fetgatter</b>
<b>Date:</b>	<b>3/10/2025</b>
<b>Impact:</b>	<b>\$0</b>

**Research Analysis**

The committee substitute to HB 2459 exempts mobile food vehicles that did not have an automatic fire extinguishing system prior to July 1, 2024 from the requirement to install them according to current code, as long as they have portable fire extinguishers installed in their vehicles. A six liter Class K-rated portable fire extinguisher is required for all cooking equipment involving solid fuels or vegetable oils, animal oils, or fats. All mobile food vehicles that utilize liquified petroleum gas are to be inspected by the Oklahoma Liquified Petroleum Gas Board. Additionally, the measure requires the State Fire Marshal to inspect and issue operational permits annually to mobile food vehicles. The provisions of this measure expire July 1, 2026.

Prepared By: Keana Swadley

**Fiscal Analysis**

The CS to HB2459 sets forth certain inspection requirements to be conducted by the Oklahoma Liquified Petroleum Gas Board and/or the Oklahoma State Fire Marshal. These provisions are anticipated to be in accordance with the normal duties of these entities. Therefore, in its current form, HB2459 is not anticipated to have a material impact on state budget or appropriations.

Prepared By: Robert Flipping IV, House Fiscal Staff

**Other Considerations**

None.